



Unit 10/78 Willandra Drive Epping Vic 3076 | 03 9401 4885|

E-mail: info@aussiegreenlighting.com.au

Web: www.aussiegreenlighting.com.au


SUPREME LED HIGH BAY | SP

SPECIFICATIONS

| Power | 50W | 60W | 75W | | |
|-------------------|------------------------------------|---------|---------|--|--|
| Lumen | 11000lm | 13200lm | 16500lm | | |
| Input Voltage | AC220~240V,50Hz | | | | |
| ССТ | 3000K,4000K,5000K | | | | |
| IP Rating | IP 65 | | | | |
| Beam Angle | 120° | | | | |
| CRI | Ra > 80 | | | | |
| LED Chips | SMD 2835 | | | | |
| Sensor | Daylight & Microwave Motion Sensor | | | | |
| Dimmable | PWM | | | | |
| Cable | 1.2 Metres+AU plug | | | | |
| Accessories | Trinity Installed Chain & Remote | | | | |
| Product Size (mm) | D258X147 | | | | |










PACKING

| N.W.(KG) | G.W.(KG) | CARTON SIZE(mm) | QTN/CTN |
|----------|----------|-----------------|---------|
| 7.5 | 9 | 520X520X165 | 4 |

REMOTE CONTROLLER

Factory setting: When turn on the High Bay light, sensor function is closed; if you need to open the sensor, please use our remote controller as below. Sensor default setting: daylight (OFF), motion(2 seconds), hold time (2 seconds), standby brightness 0%.



FUNCTION DEMO-ON/OFF CONTROL



With insufficient daylight, even when motion detected. light remains OFF.



With insufficient daylight, even when motion detected. light ON.



After the last detection and the present hold time elapsed.light OFF.

SENSOR SPECIFICATION

Detection Patterns

Technical data

| VDC ± 2v | |
|---|--|
| | |
| | |
| 20°C ~ +60°C | |
| 0%/75%/50%/20% | |
| Sec/30Sec/60Sec/2Min/5Min/15Min/30Min/60Min | |
| ux/25Lux/50Lux/100Lux/300Lux/600Lux/Disable | |
| 1mW | |
| 8GHz ± 75MHz | |
| Max.12m(ceiling mounted) | |
| Diameter 14m (ceiling mounted) | |
| Built-in | |
| 8 | |

Note: Sensor setting please refer to remote control

